

**Anthony Esson, Architect
PO Box 479
Gaylord, Michigan 49734**

**Ellsworth Community Schools
Elementary School Remodeling and Partial Reroofing
Ellsworth, Michigan**

June 18, 2025

Project No. 298-25

ADDENDUM NO. 1

This Addendum is being issued for the purpose of modifying and/or clarifying the original Bidding Documents dated May 9, 2025 and shall take precedence over them.

All work included herein shall be in accordance with the general requirements of the original bidding documents, except as specifically noted herein.

This Addendum is being sent to all known plan holders, suppliers, plan rooms, and governmental agencies having received Bidding Documents.

Supplemental Documents Issued: None

- Item No. 1: Roof Coring Data: Existing Roof System is PVC Roofing over 2" Polyisocyanurate Insulation on a Tectum (Cementitious Wood Fiber) Deck. Record Drawings indicate the deck thickness to be 3".
- Item No. 2: Due Date for RFI's for inclusion in final Addendum: RFI's from Bidders received by the end of business June 26, 2025 will be responded to by Addendum to be issued June 30, 2025.

END OF ADDENDUM NO. 1